



ADDENDUM NO. 3

Date of Issue: June 7, 2019

To all prospective bidders on the Work titled:
Ventura Street Water Main Replacement (Specification No. 18-404).

The Drawings and Project Manual including Specifications are modified as follows. This Addendum forms a part of the Contract Documents and modifies the original documents dated May 3, 2019.

Acknowledge receipt of this Addendum in the space provided in the Bid Schedule. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 2 pages.

Item AD3-1

Questions

- Question 1: Clarification is needed in the Arborist Report and Tree Protection Plan. I expect we will be encountering a lot of roots that are 2" and larger. Who is responsible for making the decision on root pruning and who is responsible for the reporting? Is the District expecting the Contractor to supply a Certified Arborist to monitor full time during the project?
- Response 1: The District will provide an arborist. The District or its representative will make the determination on root pruning and will report to the City. The Contractor is not responsible for providing an arborist.
- Question 2: Can you supply an estimate for the Road Encroachment Permit fees?
- Response 2: Contractor to contact the City of Ojai for encroachment permit cost estimates.
- Question 3: The plans call for a new 2" service for 122 E Ojai Ave. Is it located in the sidewalk and no tie in is required?
- Response 3: Yes, install the meter box in the sidewalk. This is for a future connection.
- Question 4: Per Addendum 2 there are 2 ea. offsets. Can you provide rough station numbers? If Contractor installs an offset does the District want both a 1" air vac and 2" blow off included in the line item?

Response 4: Offsets are tentatively located at Ventura Street stations 7+85 and 18+70 at Aliso Street and Summer Street intersections, respectively. No air vac or blow off is anticipated.

Acknowledgement:

By signature below, Bidder acknowledges Addendum No. 3.

Signed: _____

END OF ADDENDUM NO. 3