



**CASITAS MUNICIPAL WATER DISTRICT
RINCON PUMP PLANT ELECTRICAL UPGRADE
SPECIFICATION NO. 17-397**

RESPONSES TO QUESTIONS

March 29, 2019

Q. *“Could you (the District) clarify the extent of the demolition in the area of the existing SCE transformer which is to be removed by SCE after the cutover. Currently, the Plans indicate to remove only the fencing surrounding their “substation”. However there is an old steel structure within the fencing. Should that, also, be removed? Will it also be necessary to remove the Old concrete pads that will be left after the job is completed. Please advise on this issue”*

R. (1) Remove the existing steel structure within the fencing. (2) leave old concrete pad at place.

Lindsay Cao

Lindsay Cao, P.E.
Civil Engineer